

Cable ID: P8-M15-4

Test Limit: ISO Patch Cord Cat6A 1.0m

Limits Version: V7.5

Date / Time: 10/13/2021 04:34:39 PM

Headroom 1.6 dB (NEXT 3,6-4,5)

Cable Type: Cat 6A F/UTP

NVP: 74.0%

Main: Versiv

S/N: 1707014

Software Version: V6.5 Build 5

Calibration Date: 09/21/2020

Adapter: DSX-8000 (DSX-PC6A)

S/N: 3661361

Test Summary: PASS

Remote: Versiv

S/N: 1707027


Software Version: V6.5 Build 5

Calibration Date: 09/21/2020

Adapter: DSX-8000R (DSX-PC6A)

S/N: 3661383

Length (ft)	[Pair 1,2]	4
Prop. Delay (ns)	[Pair 4,5]	6
Delay Skew (ns)	[Pair 3,6]	1
Resistance (ohms)	[Pair 3,6]	0.17



Wire Map (T568B)





PASS



Worst Case Margin Worst Case Value

PASS	MAIN	SR	MAIN	SR
Worst Pair	3,6-4,5	3,6-4,5	3,6-4,5	3,6-4,5
NEXT (dB)	1.6	1.7	2.3	1.8
Freq. (MHz)	281.0	286.0	500.0	500.0
Limit (dB)	37.8	37.6	31.0	31.0

PASS	MAIN	SR	MAIN	SR
Worst Pair	3,6	3,6	3,6	3,6
RL (dB)	0.6	0.2*	1.3	1.4
Freq. (MHz)	317.0	309.0	422.0	414.0
Limit (dB)	12.5	12.6	10.6	10.7



* Measurement is within the accuracy limits of the instrument.